

PG- PORTABLE GENERATOR PERMITS



NO GASOLINE
GENERATORS!!!!!!

WHY NO GASOLINE GENERATORS?

GASOLINE IS HIGHLY FLAMMABLE, AND A GENERATOR RUNNING FOR LONG PERIODS OF TIME MAKES THE UNIT EXTREMELY HOT, REFUELING OPERATIONS COULD RESULT IN A FLASH FIRE FROM SPILLAGE OF FUEL.



DIESEL OF PROPANE FUELED GENERATORS ARE PERMITTED



STATIONARY GENERATORS



- ALSO REQUIRES A PERMIT FROM ISD ELECTRICAL
- MUST BE PROPERLY GROUNDED
- MINIMUM 2A:20BC EXTINGUISHER REQUIRED
- MUST BE BARRICADED FROM PUBLIC (FENCE, JERSEY BARRIERS)
- EACH GENERATOR WILL REQUIRE ITS OWN PERMIT, UNLESS IDENTICAL GENERATORS (SAME MAKE, MODEL, WATTAGE)

MOST COMMONLY USED GENERATORS

DIESEL OR PROPANE FUELED



FILE FOR BFD PORTABLE GENERATOR PERMIT

1. SUBMIT SPEC SHEET OF GENERATOR
2. SUBMIT BASIC SITE OF GENERATOR LOCATION



WHAT INSPECTOR'S WILL LOOK FOR?

1. GENERATOR IS SAME MAKE AND MODEL THAT WAS SUBMITTED ON APPLICATION
2. YOU HAVE A MINIMUM 2A:20BC EXTINGUISHER ON SITE
3. GENERATOR IS BARRICADED FROM PUBLIC ACCESS

SOLAR AND BATTERY POWERED GENERATORS



Storage Systems 5kW and above require BFD Permit.

