

*PERMEABLE PAVERS SHALL BE INSTALLED WITH A MINIMUM WIDTH OF 18" FOR SIDEWALKS UP TO 7'. FOR SIDEWALKS OVER 7', PERMEABLE PAVER WIDTH SHALL BE 1' PER 5' OF SIDEWALK.

NOTE:

DEPENDING ON SOIL CONDITIONS AND GROUNDWATER, IT MAY BE APPROPRIATE TO PROVIDE AN UNDERDRAIN BEHIND THE CURB AND WITHIN THE CRUSHED STONE BASE. UNDERDRAIN MAY BE REQUIRED IN SOILS WITH LOW INFILTRATION RATES. IF USED, THEY MUST BE INSTALLED ABOVE THE GROUNDWATER ELEVATION.

ALL PERMEABLE SYSTEMS SHALL BE MAINTAINED AS PER MANUFACTURER RECOMMENDATIONS.

BOSTORIA OB RECOMPTIANCE ON THE OWNER RECOMPTIANCE OWNER RECOMP	Public Works Department Engineering Division	SIDEWALK - PERMEABLE PAVER	DATE OF ISSUE: SEPTEMBER 2018	
	1 CITY HALL SQUARE, ROOM 710 BOSTON, MA 02201 (617) 635-4968		SCALE: N.T.S.	S.4